


DIN-DVGW-Baumusterprüfzertifikat

DIN-DVGW type examination certificate

NG-5180AQ1267

Registriernummer
registration number

Anwendungsbereich <i>field of application</i>	Produkte der Gasversorgung <i>products of gas supply</i>
Zertifikatinhaber <i>owner of certificate</i>	Berry Plastics BVBA Nijverheidsstraat 10, B-2260 Oevel (Westerlo)
Vertreiber <i>distributor</i>	Berry Plastics BVBA Nijverheidsstraat 10, B-2260 Oevel (Westerlo)
Produktart <i>product category</i>	greasing and sealing materials: Protection tape against corrosion (5180)
Produktbezeichnung <i>product description</i>	warm applicable coating repair system
Modell <i>model</i>	PERP
Prüfberichte <i>test reports</i>	laboratory control test: 10/160/5180/014 from 20.08.2010 (EBI)
Prüfgrundlagen <i>basis of type examination</i>	DIN 30672 (01.12.2000) DIN EN 12068 (01.03.1999)
Ablaufdatum / AZ <i>date of expiry / file no.</i>	31.08.2015 / 10-0564-GNV

30.08.2010 Rie A-1/2 

Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle
date, issued by, sheet, head of certification body

DVGW CERT GmbH - von der Deutschen Akkreditierungsstelle Technik (DATech)
in der TGA GmbH akkreditiert für die Konformitätsbewertung von Produkten der
Gas- und Wasserversorgung

DVGW CERT GmbH - accredited by Deutsche Akkreditierungsstelle Technik
(DATech) in the TGA GmbH for conformity assessment of products of gas and
water supply



DVGW CERT GmbH
Josef-Wirmer-Straße 1-3
53123 Bonn

Telefon: +49 228 91 88-888

Telefax: +49 228 91 88-993

eMail: info@dvw-cert.com

DAT-ZE-009/96-02

Typ <i>type</i>	Technische Daten <i>technical data</i>	Bemerkungen <i>remarks</i>
PERP	stress-class: C permanent operating temperature: +50 °C	

Verwendungshinweise / Bemerkungen***hints of utilization / remarks***

Application: to melt on with luminous flame, coating defect before with PERT fountain pen compensate

Compatibility: Polyethylene (PE)-wrappings

Designation according to standard: wrapping EN 12068-C 50 and DIN 30672-C 50